

Government of Nepal
Ministry of Communication and Information Technology
National Information Technology Development Committee
National Information Technology Center
Singhadurbar, Kathmandu, Nepal

Addendum Notice No. 1

2079/03/31 (July 15, 2022)

This is to notify all concerned that Ministry of Communication and Information Technology, National Information Technology Development Committee, National Information Technology Center, Singhadurbar, Kathmandu has made the following amendments to the Bidding Documents for the “**Construction of Data Center and Internet Exchange Center at Khumaltar, Lalitpur**, IFB No.: NITC/W/NCB-19/078-79” as per the notice published on 2079/03/2 (June 16, 2022) in “the Rising Nepal” national daily newspaper and www.bolpatra.gov.np/egp.

Reference of Bid Document	Existing Clause	Amendment
Invitation for Bids, Point No. 6, Page 4	Electronic bids must be submitted to the office National Information Technology Center, (NITC) Singhadurbar, Kathmandu, Nepal through PPMO's e-GP system www.bolpatra.gov.np/egp on or before 12:00 noon on July 17, 2022.	Electronic bids must be submitted to the office National Information Technology Center, (NITC) Singhadurbar, Kathmandu, Nepal through PPMO's e-GP system www.bolpatra.gov.np/egp on or before 12:00 noon on July 24, 2022.
Invitation for Bids, Point No. 7, Page 4	The bids will be opened in the presence of Bidders' representatives who choose to attend at 1:00 PM on July 17, 2022 at the office of National Information Technology Center, (NITC) Singhadurbar, Kathmandu, Nepal.	The bids will be opened in the presence of Bidders' representatives who choose to attend at 1:00 PM on July 24, 2022 at the office of National Information Technology Center, (NITC) Singhadurbar, Kathmandu, Nepal.
Section II: Bid Data Sheet, ITB 22.1, Page 35	The deadline for bid submission is: Date: July 17, 2022 Time: 12:00 Noon	The deadline for bid submission is: Date: July 24, 2022 Time: 12:00 Noon
Section II: Bid Data Sheet, ITB 25.1, Page 35	The Technical Bid opening shall take place at: National Information Technology Center, Singhadurbar, Kathmandu Date: July 17, 2022 Time: 1:00 PM	The Technical Bid opening shall take place at: National Information Technology Center, Singhadurbar, Kathmandu Date: July 24, 2022 Time: 1:00 PM
IFB, Page no. 277 Section VI, Works Requirements, Specifications, Part 3000 Electrical and Allied Works, 3004 Diesel Generator	3004.1 General This Section includes 4 MVA Diesel Power Plant, consisting 2 sets x 1800 kVA Stationary Diesel Generating Sets, as a Prime Power Supply Units during the breakdown period of the city mains supply.	3004.1 General This Section includes 2 x 1800 kVA Stationary Diesel Generating Sets, as a Prime Power Supply Units during the breakdown period of the city mains supply.
IFB, Page no. 277 Section VI, Works Requirements, Specifications, Part 3000 Electrical and Allied Works, 3004 Diesel Generator	3004.4 Applicable Standards, Codes, and Regulations The Diesel Generator sets shall conform to the following standards: a) CE certification and the corresponding Declaration of Conformity complying with R.D 842/2002 Low Voltage Regulations and with the European Directives b) 2006/42 on Safety in Machinery	3004.4 Applicable Standards, Codes, and Regulations The Diesel Generator sets shall conform to the following standards: a) CE certification and the corresponding Declaration of Conformity complying with R.D 842/2002 Low Voltage Regulations and with the European Directives b) 2006/42 on Safety in Machinery

- c) 2006/95/CE on Electrical Safety.
- d) 2004/108/CE on Electromagnetic Compatibility.
- e) 2005/88/CE on NOISE EMISSIONS by equipment for outdoor use (for SOUNDPROOF GENERATOR SETS)
- f) ISO 8528

The Engine shall conform to the following standards:

- a) BS-5514
- b) IS-10000
- c) ISO-3046
- d) BS-649
- e) DIN-6271

The Alternator shall conform to the following standards:

- a) IEC 34-1-1983
- b) IP-21
- c) IS-4691/85
- d) BS-269
- e) IS13364
- f) BS EN 60034
- g) BS5000
- h) VDE 0530
- i) NEMA
- j) MG1-32
- k) IEC34
- l) CSA
- m) C22.2-100
- n) AS1359

The Acoustic Canopy shall conform to the following standards:

- a) ISO-3744
- b) ISO-8528
- c) ISO-9614
- d) IS-8183

The Control Panels shall conform to the following standards:

- a) BS EN 61000-6-2
- b) BS EN 61000-6-4
- c) BS EN 60950
- d) BS EN 60068
- e) BS EN 60529
- f) IP65
- g) IS-4722
- h) IS-2147

- c) 2006/95/CE on Electrical Safety.
- d) 2004/108/CE on Electromagnetic Compatibility.
- e) 2005/88/CE on NOISE EMISSIONS by equipment for outdoor use (for GENERATOR SETS)
- f) ISO 8528

IFB, Page no. 469
Section X: Contract Forms,
Bidder's Compliance Sheet
2 Diesel Generator Set

2.4 Applicable Standards, Codes, and Regulations

The Diesel Generator sets shall conform to the following standards:

- CE certification and the corresponding Declaration of Conformity complying with R.D 842/2002 Low Voltage Regulations and with the European Directives
- 2006/42 on Safety in Machinery

2.4 Applicable Standards, Codes, and Regulations

The Diesel Generator sets shall conform to the following standards:

- CE certification and the corresponding Declaration of Conformity complying with R.D 842/2002 Low Voltage Regulations and with the European Directives
- 2006/42 on Safety in Machinery

- 2006/95/CE on Electrical Safety.
- 2004/108/CE on Electromagnetic Compatibility.
- 2005/88/CE on NOISE EMISSIONS by equipment for outdoor use (for SOUNDPROOF GENERATOR SETS)
- ISO 8528

The Engine shall conform to the following standards:

- BS-5514
- IS-10000
- ISO-3046
- BS-649
- DIN-6271

The Alternator shall conform to the following standards:

- IEC 34-1-1983
- IP-21
- IS-4691/85
- BS-269
- IS13364
- BS EN 60034
- BS5000
- VDE 0530
- NEMA
- MG1-32
- IEC34
- CSA
- C22.2-100
- AS1359

The Acoustic Canopy shall conform to the following standards:

- ISO-3744
- ISO-8528
- ISO-9614
- IS-8183

The Control Panels shall conform to the following standards:

- BS EN 61000-6-2
- BS EN 61000-6-4
- BS EN 60950
- BS EN 60068
- BS EN 60529
- IP65
- IS-4722
- IS-2147

- 2006/95/CE on Electrical Safety.
- 2004/108/CE on Electromagnetic Compatibility.
- 2005/88/CE on NOISE EMISSIONS by equipment for outdoor use (for GENERATOR SETS)
- ISO 8528